

UKOPA

United Kingdom Onshore Pipeline Operators' Association

Good Practice Guide

Seismic Screening Assessment of UK Onshore Pipelines and Associated Installations

UKOPA/GPG/019 Ed 2

February 2026

GUIDANCE ISSUED BY UKOPA:

The guidance in this document represents what is considered by UKOPA to represent current UK pipeline industry good practice within the defined scope of the document. All requirements should be considered guidance and should not be considered obligatory against the judgement of the Pipeline Owner/Operator. Where new and better techniques are developed and proved, they should be adopted without waiting for modifications to the guidance in this document

Comments, questions, and enquiries about this publication should be directed to:

UK Onshore Pipeline Operators' Association

Ripley Road
Ambergate
Derbyshire
DE56 2FZ

E-mail: secretary@ukopa.co.uk

Website: www.ukopa.co.uk

Disclaimer

This document is protected by copyright and may not be reproduced in whole or in part, by any means without the prior approval in writing of UKOPA. The information contained in this document is provided as guidance only and while every reasonable care has been taken to ensure the accuracy of its contents, UKOPA cannot accept any responsibility for any action taken, or not taken, on the basis of this information. UKOPA shall not be liable to any person for any loss or damage which may arise from the use of any of the information contained in any of its publications. The document must be read in its entirety and is subject to any assumptions and qualifications expressed therein. UKOPA documents may contain detailed technical data which is intended for analysis only by persons possessing requisite expertise in its subject matter.

Copyright @ 2026, UKOPA. All rights reserved.

Revision and change control history

Planned revision: 2031

Edition	Date	No. of pages	Summary of changes
1	31/01/2019	22	Prepared by UKOPA PIWG and published
2	01/02/2026	18	Editorial review, update of reference standards

CONTENTS

1	Executive summary	1
2	Introduction	2
2.1	Background	2
2.2	Scope	2
2.3	Application	3
3	Seismic Hazard Assessment	4
3.1	Report on Seismic Hazard to UK Pipelines and Associated Installations	4
3.1.1	Earthquakes	4
3.1.2	Seismic Hazard	5
3.2	Review of NGT Seismic Policy	6
3.3	UK Seismicity Levels	7
3.4	ISO 20074	7
4	Seismic Assessment	9
4.1	Screening Methodology for Pipelines and Associated Installations	9
4.2	Screening Methodology	9
4.3	Importance Classification	9
4.4	Importance Factor	10
4.5	Peak Ground Acceleration (PGA)	10
4.6	Screening Criteria	12
4.7	Worked Examples	13
5	Conclusion and Recommendation	14
6	References	15
Appendix A	Example Consequence Descriptions	16
A.1	Safety	16
A.2	Example Economic, Social and Environmental Consequences	16
Appendix B	Worked Examples	17

1 EXECUTIVE SUMMARY

This United Kingdom Onshore Pipeline Operators' Association (UKOPA) good practice guide (GPG) has been developed by the UKOPA Pipeline Integrity Working Group (PIWG) to provide guidance on the seismic screening assessment for UK onshore pipelines and associated installations. The guidance within the document is applicable to all buried pipelines operated by the UKOPA member companies.

The advice in this document is based on a detailed review of the requirements of published standards carried out for UKOPA and work to develop the National Grid - now National Gas Transmission (NGT) - technical specification for the seismic engineering of natural gas pipelines and associated installations operating at above 7 barg.

The detailed review of the requirements of published standards was carried out to inform compliance requirements for seismic assessment of pipelines and installations in the UK.

The NGT work was developed to comply with the requirements of Eurocode 8, the UK national annexes and BSI PD 6698, and were provided to UKOPA by NGT for inclusion in this UKOPA guidance.

ISO 20074 is used by pipeline operators and designers for the implementation of and improvement of geological hazard risk management for onshore pipeline systems. The pipeline system includes the pipeline, the right of way, and all associated buried and above ground facilities.

The document provides guidance on a screening methodology for the seismic assessment of operating pipelines and installations for use by UKOPA members. The screening methodology is based on:

- Assignment of Importance Classification according to the consequences of failure.
- Assignment of the Importance Factor based on the Importance Classification.
- Calculation of seismic action parameters:
 - Ground acceleration (using the seismic hazard map given in PD 6698).
 - Soil factor (using Table 3.3 in BS EN 1998-1).
- Application of ground acceleration criteria.

It is recommended the screening methodology presented is used to identify regions of the UK in which the seismic assessment of pipelines and installations is unnecessary, and to determine where further detailed assessment is required to ensure seismic risks are understood and managed.

2 INTRODUCTION

2.1 Background

The requirement for an operator GPG for a screening methodology for the seismic assessment of pipelines and associated installations has been identified by the UKOPA PIWG to ensure compliance with recognised pipeline standards.

The advice in this document is based on a detailed review of the requirements of published standards carried out for UKOPA [1], a briefing paper which reviewed the National Grid - now National Gas Transmission (NGT) - policy, management procedure and technical specification for the seismic engineering of natural gas pipelines and associated installations operating at above 7 barg [2], and ISO 20074 Geological hazard risk management for onshore pipeline [3]. The detailed review of the requirements of published standards was carried out to inform compliance requirements for seismic assessment of pipelines and installations in the UK.


The NGT technical specification was developed to comply with the requirements of Eurocode 8 [4, 5, 6, 7, 8, 9], the UK national annexes [10, 11, 12, 13, 14] and BSI PD 6698 [15]. NGT provided the technical work used to develop this specification to UKOPA for review. The results of the review are included in the UKOPA guidance.

ISO 20074 is intended for use by pipeline operators and designers for the implementation of and improvement of geological hazard risk management for onshore pipeline systems. The pipeline system includes the pipeline, the right of way, and all associated buried and above ground facilities. The guidance on the geological risk management of pipelines and installations subject to seismic hazards is summarised in this GPG.

2.2 Scope

This GPG provides guidance on a screening methodology for assessing the risks posed by seismic activity to onshore UK pipelines and their associated installations. Application of the methodology will identify regions of the UK where the seismic assessment of pipelines and installations is unnecessary and will determine when further detailed assessment is required to ensure seismic risks are understood and managed.

The extent of the pipeline system to which this GPG applies is defined as the assets from the pipeline inlet valve to the outlet valve, including any associated installations (i.e. launch and receive pig traps, block valves, pressure regulation and/or metering installations, multi junctions) and spur connections. Compressor stations, pump stations, refineries and storage facilities are not included. The pipeline system is shown in Figure 1.



Not included in scope:

- Compressor/pump stations
- Refineries
- Storage Facilities

Figure.7 ¿Extent.of.pipeline.system.covered.by.this.GPG

2.3 Application

The guidance in this document is applicable to all buried pipelines operated by the UKOPA member companies.

Within this document:

Shall: indicates a mandatory requirement.

Should: indicates good practice and is the preferred option.

3 SEISMIC HAZARD ASSESSMENT

3.1 Report on Seismic Hazard to UK Pipelines and Associated Installations

A brief description of the seismic hazard to UK pipelines and the associated installations is given below.

The history of seismic hazard assessment for engineered structures in the UK and the decisions on appropriate annual probability of exceedance values (return periods) for seismic actions is given in the References in Section 6. The underlying cause of British earthquakes is discussed based on the extensive work of the British Geological Survey (BGS). The requirements for seismic design to Eurocode 8 and the variations through UK National Annexes and guidance from PD 6698 [15] are presented. The review clarifies the need to demonstrate the adequacy of the seismic resilience of major accident hazard pipelines and installations, either by virtue of the low seismic hazard or the low vulnerability achieved by structural design.

The inherent low vulnerability of modern welded steel pipelines to seismic hazard is demonstrated through a review of pipeline performance in past earthquakes. Seismic hazard in the UK is presented in terms of peak ground motions and seismic intensity (a measure of damage potential) at several return periods. This allows the significance of the return period on the seismic hazard to be illustrated and for the regional variation in natural seismic activity to be presented. Possible criteria are then presented and discussed for the potential screening of seismic hazard to enable an appropriate level of assessment and design to be determined.

The conclusions are summarised as:

3.1.1 Earthquakes

Earthquakes are a release of strain energy due to the fracture of rock and the transmission of some of that energy as seismic waves.

Natural earthquakes in the UK are attributed to the failure and movement of existing geological fault structures primarily due to crustal compression associated with tectonic plate movements.

Induced earthquakes in the UK have been attributed to underground mine collapses, rock blasting and hydraulic fracturing in deep boreholes. Hydraulic fracturing includes oil and gas reservoir stimulation, geothermal reservoir stimulation and shale gas extraction (fracking).

Earthquakes can be quantified in terms of a magnitude scale according to the amount of energy released. Several magnitude scales exist according to the determination method. The cumulative number of earthquakes in a region above a particular magnitude is found to decrease with magnitude according to the Gutenberg-Richter log-linear relationship. On average, the UK may expect a local magnitude 3.7 earthquake every year, a magnitude 4.7 earthquake every 10 years and a magnitude 5.6 earthquake every 100 years.

The threshold earthquake magnitude of engineering significance is a moment magnitude of ~4.5. There have been ~27 earthquakes across the UK of this magnitude or greater in a ~300 year period.

The anticipated maximum magnitudes for natural and induced earthquakes in the UK are:

- Natural 5.5 to 6.5
- Mining 3.2 to 3.5
- Geothermal 1.9
- Fracking ~3.0

Natural earthquake activity is variable across the UK mainland showing higher levels of activity in the west than in the south and east of the country.

Earthquake effects at surface can be measured quantitatively in terms of ground motions or assessed qualitatively through the observed damage. The normal ground motion measurement is the variation of horizontal and vertical ground acceleration with time which can be integrated to obtain velocity and displacement ground motions. Damage is assessed and assigned to a seismic intensity scale. Several intensity scales exist although the scales in most common usage are the 12-point Modified Mercalli Scale and the 12-point European Macroseismic Scale.

3.1.2 Seismic Hazard

Seismic hazards to buried pipelines and above-ground installations include:

- Transient loading due to seismic wave propagation (ground shaking).
- Permanent ground movement due to:
 - Geological fault displacement at surface.
 - Ground movement due to slope instability.
 - Ground movement due to liquefaction.

Seismic hazard assessment in the UK has been under development since the early 1970's with particular motivation from the nuclear industry. Earthquake instrumental monitoring in the UK has expanded since the early 1970's to reach a current network of over 100 stations operated by the BGS.

A seismic hazard study completed in 1991 for the Department for Environment, Food & Rural Affairs, concluded that there was no justification for the inclusion of earthquake resistance into the design of conventional structures. However, certain structures whose failure could pose a hazard to a significant number of people should incorporate earthquake loading in their design. The study identified an outstanding need for guidance on how to decide if a structure or installation was sufficiently hazardous to justify a seismic design.

Eurocode 8 for the seismic design of structures in Europe was issued in 2005 and 2006. The National Annexes for the UK decisions on nationally determined parameters for the application of Eurocode 8 in the UK were issued in 2008 and 2009. The UK National Annexes are supported by PD 6698 issued in 2009.

The UK decision on seismic design is that there are no requirements for most structures, but certain types of structure may warrant an explicit consideration of seismic actions. PD 6698 identifies major

hazard sites and major accident hazard pipelines as categories of structure that should be designed to withstand very low probability events, including earthquakes.

Facilities assessed as posing a large risk to the population or to the environment require a site-specific hazard assessment to establish appropriate design ground motions. Other high consequence facilities may use the peak ground acceleration (PGA) according to a seismic hazard map in PD 6698 for a return period of 2500 years (annual probability of exceedance of 4×10^{-4}), reproduced in Figure 2.

A particular challenge for major accident hazard pipeline operators is to interpret which pipelines and installations should be considered for seismic design and whether the seismic hazard assessment approach should be based on a hazard map or a site-specific assessment.

3.2 Review of NGT Seismic Policy

A comprehensive technical study by consultants working on seismic policy development for NGT was provided to UKOPA for review.

NGT used the results of this technical study to develop policy, management procedure and technical specification documents for the seismic engineering of onshore UK pipelines and associated installations operating at above 7 barg.

A review for UKOPA presents the key technical aspects of the work and considers the approach relative to practices elsewhere in regions with similar levels of seismicity.

The key aspects are:

- The selection of Importance Classes and the assignment of return periods for the design seismic ground motion.
- The use of a partial factor to increase ground motions from a PD 6698 seismic hazard map.
- A screening criterion to identify the required level of seismic design.
- The selection of an acceleration level for simplified seismic design.

The report details the screening methodology developed by NGT and included in their specification for the determination of seismic design requirements. Key factors identified are:

- The screening methodology applies a ground acceleration value of 0.1 g.
- Probabilistic hazard maps offer the best means to represent the uncertainties and establish ground motion values for design in intra plate regions such as Northern Europe, where earthquake sources are not well defined and maximum magnitude events have long return periods.
- The specification incorporates a partial factor $\gamma_f = 1.5$ to increase the ground motion from the hazard map. This accounts for the maximum horizontal component of ground motion exceeding the geometric mean and for the possibility that the hazard map will underestimate the ground motion level. There is no evidence from the USA or Europe to suggest that ground motion values from hazard maps are routinely increased to account for the measure of ground motion or the way the values are calculated. It is therefore concluded the removal of the partial factor

$y_f = 1.5$ from the procedure can be justified on the basis of practice elsewhere, and this will not adversely affect the rigour of the approach.

The report recommends that UKOPA should consider use of the approach in terms of:

- The Importance Classification of pipelines, piping and other structures according to the number of potential casualties within the hazard range and the importance of security of supply.
- The selection of return periods for the determination of seismic actions for design.
- The usage of ground motion values from hazard maps.
- Screening for the exclusion of seismic design, for the selection of simplified seismic design or for full seismic design.

UKOPA understands that regarding the definition of Importance Classification, the NGT definition cannot be directly applied to liquid pipelines and may not be directly applicable to gas pipelines where supply is a business issue and not a matter of national security. Amendments to this statement to make it more inclusive to all UKOPA members are proposed in this document.

3.3 UK Seismicity Levels

The implied areas of the UK classified as 'very low' seismicity and 'low' seismicity for Class IV structures to EN 1998-4:2006 are shown in Figure 2. Class IV refers to situations with exceptional risk to life and extreme economic, social or environmental consequences. Certain categories of structure in areas of 'very low' seismicity need not, subject to national approval, meet the provisions of EN 1998. Certain types or categories of structure in areas of 'low' seismicity may be designed according to reduced or simplified procedures.

The UK national annex to EN 1998-1 declares the whole of the UK as a region of 'very low' seismicity based on $a_g \leq 1.8 \text{ m/s}^2$ ($\sim 0.18 \text{ g}$) for a return period of 2500 years.

3.4 ISO 20074

The purpose of ISO 20074 is the orderly and effective identification, assessment and mitigation of geological hazards threatening the safety of the pipeline system, to reduce risk and accidental loss as well the occurrence of pipeline damage. The pipeline system includes the pipeline, the right of way and all associated buried and above ground facilities. It is applicable to landslides, rockfalls, debris flows, land subsidence, permafrost, collapsible soil, saline soil, gully erosion, slope erosion, and earthquake. The document covers preliminary engineering, route selection, detailed design, construction, operation and maintenance.

The document states that operators shall establish, implement, maintain and document a geological hazard risk management program and continually improve its effectiveness. The geological risk management program covers three operating procedures:

- Risk identification.
- Risk assessment.
- Risk mitigation.

In terms of the operating and maintenance phase of the pipeline system, the document states that risk identification includes identified earthquake fault zones and active faults seismic ground motion parameter curves applied during preliminary engineering. Identified risks due to earthquake fault zones and active faults should be subject to risk assessment, which will then dictate risk mitigation measures. The risk assessment should assess earthquake faults taking account of location, type, predicted magnitude, displacement and return period.

Example complexity classification of geological environmental conditions for earthquakes are given in Annex C of ISO 20074 with seismic peak ground acceleration (PGA) values as follows:

- High: Exceeds 0.2 g
- Medium: 0.1 to 0.2 g
- Simple: Less than 0.1 g

The seismic PGA recommended for the simple classification is equivalent to the screening criterion applied in the NGT screening approach.

4 SEISMIC ASSESSMENT

4.1 Screening Methodology for Pipelines and Associated Installations

The seismic assessment screening methodology for application to operating pipelines and installations described below is based on that developed by NGT for seismic design of new pipelines and installations, excluding the partial factor $\gamma_f = 1.5$, to increase the ground motion from the hazard map and modified to cover environmental hazards in the definition of Importance Classification.

4.2 Screening Methodology

The seismic assessment screening methodology applied to pipelines and above-ground installations in a particular location involves the following four steps:

1. Assignment of Importance Classification according to the safety, economic, social and environmental consequences of failure.
2. Assignment of Importance Factor based on the Importance Classification.
3. Calculation of seismic action parameters:
 - a. Ground acceleration (using the seismic hazard map given in PD 6698)
 - b. Soil factor (using Table 3.3 in BS EN 1998-1).
4. Application of threshold ground acceleration criteria.

4.3 Importance Classification

The seismic assessment requirements for pipelines and installations and pipelines are determined according to an Importance Classification, defined by the safety, economic, social and environmental consequences of failure. The Importance Classification is assigned as shown in Table 1:

Safety	Economic, Social and Environmental Consequences		
	Low	Considerable	Great
Low	I	II	III
Medium	II	II	III
High	III	III	III

Notes:
 Class I Refers to situations where risk to life is low, and economic, social and environmental consequences of failure are low
 Class II Refers to situations with medium risk to life, and considerable economic, social or environmental consequences of failure
 Class III Refers to situations with high risk to life, and great economic, social and environmental consequences of failure

Table.7 Importance classification of pipelines and installations

The Importance Classification is assigned by the operator. Example descriptions of consequences are provided for guidance in Appendix 1.

Guidance on environmental risk assessment is provided by the Chemical and Downstream Industries Forum (CDOIF) [16].

4.4 Importance Factor

The Importance Classification is used to assign an Importance Factor value, y_i , which is used to select an appropriate return period for the seismic action. The Importance Factor y_i values are as in Table 2:

Importance Class	I	II	III
Importance Factor y_i	n/a	0.45	1.0

Table.8;Importance.factors.assigned.to.importance.classes

4.5 Peak Ground Acceleration (PGA)

The ground acceleration on rock, a_g , is calculated as follows:

$$a_g = y_i \times a_{Gr}$$

Where:

y_i is the Importance Factor

a_{Gr} is the reference PGA on rock for a return period of 2500 years, given in PD 6698

The seismic hazard map for PGA on rock given in PD 6698 for a return period of 2500 years is given in Figure 2.

The ground acceleration on soil is calculated as:

$$a_g \times S$$

Where:

S is the soil factor, given in BS EN 1998-1.

Table 3 shows the ground type, description and associated soil factor.

Ground Type	Description	S
A	Rock	1.0
B	Very dense granular deposits or very stiff clays	1.35
C	Dense to medium dense granular deposits or stiff clays	1.5
D	Loose to medium dense granular deposits or soft to firm clays	1.8
E	Type C or D (5 to 20 m) overlying rock	1.6

Table.9;Ground.type.and.soil.amplification.factors

The ground type definitions follow a convention set out by the BGS and can be referenced from the BGS GeoSure dataset.




Figure.8; Seismic hazard map for PGA on rock.
(Contains British Geological Survey materials.' NERC.867)

4.6 Screening Criteria

The threshold value of the ground acceleration is:

$$a_{g,S} = 0.1 \text{ g}$$

Where $a_{g,S} \leq 0.1 \text{ g}$, seismic assessment is not required for buried pipelines in any Importance Class, and installations in Importance Class I or II.

Where $a_{g,S} > 0.1 \text{ g}$, seismic assessment is not required for buried pipelines in Importance Class I and II, and installations in Importance Class I.

Seismic assessment should be carried out for pipelines in Importance Class III, and installations in Importance Class II and above.

Note: Pipeline crossings located on bridges are subject to the seismic assessment of the bridge structure.

Seismic screening criteria are summarised in Table 4:


Importance Class	$a_{g,S} \leq 0.1 \text{ g}$		$a_{g,S} > 0.1 \text{ g}$	
	Buried Pipelines	Above-Ground Installations	Buried Pipelines	Above-Ground Installations
I	None			
II	None			Simplified
III	None	Simplified	Full	

Table 4: Application of screening criteria to pipelines and installations

For locations failing the threshold criterion of 0.1 g there is a requirement for a simplified seismic assessment of above-ground Class II systems and a full seismic design for Class III and IV pipelines and structures. The implied regional extents of these requirements are indicated in Figure 3 for two ground types, Type A 'rock' and Type D 'loose to medium dense non-cohesive ground or soft to firm cohesive ground'.

For Class II systems, Figure 3 shows the regional extent of the UK subject to some form of seismic design requirement (in this case simplified) is very limited, potentially covering locations in South Wales and North West Wales.

For Class III systems, Figure 3 shows the regional extent of the UK subject to a full seismic assessment is fairly extensive for 'soft' ground sites. The regional extent is broadly aligned with the more seismically active areas of the UK.



Note: Ground type A shown left, ground type D shown right

Figure 9: Indicative regional extent (shown in red) of seismic assessment requirements for Class II installations and Class III pipelines and installations

4.7 Worked Examples

Worked examples developed applying the seismic screening methodology at a PIWG Seismic Screening workshop are given in Appendix 2.

5 CONCLUSION AND RECOMMENDATION

It is concluded that, with the exclusion of the partial factor $y_f = 1.5$ used to increase the ground motion derived from the PD 6698 hazard map, the screening approach for seismic design for new pipelines and installations developed by NGT provides the basis of a practical screening methodology for the assessment of gas and liquid pipelines and installations operated by UKOPA members.

The seismic PGA limit of 0.1 g used in the NGT screening approach for seismic design and applied in the screening methodology for the seismic assessment of operating pipelines and installations aligns with the seismic PGA recommended for the simple classification of geological environmental conditions specified in ISO 20074.

It is recommended the screening methodology presented in Section 4 is used to identify regions of the UK in which the seismic assessment of pipelines and installations is unnecessary, and locations where further assessment is required.

6 REFERENCES

- [1] G. Leach, "Seismic Hazard to Welded Steel Pipelines in the United Kingdom," UKOPA/PO/14/84 v2.2, 2015.
- [2] G. Leach, "National Grid Seismic Policy, UKOPA Briefing Note," v1.0, 2016.
- [3] International Organization for Standardization, "Petroleum and natural gas industry — Pipeline transportation systems — Geological hazard risk management for onshore pipeline," ISO 20074, 2019.
- [4] British Standards Institution, "Eurocode 8: Design of structures for earthquake resistance - Part 1: General rules, seismic actions and rules for buildings," BS EN 1998-1, 2005.
- [5] British Standards Institution, "Eurocode 8: Design of structures for earthquake resistance - Part 2: Bridges," BS EN 1998-2, 2005.
- [6] British Standards Institution, "Eurocode 8: Design of structures for earthquake resistance - Part 3: Assessment and retrofitting of buildings," BS EN 1998-3, 2006.
- [7] British Standards Institution, "Eurocode 8: Design of structures for earthquake resistance - Part 4: Silos, tanks and pipelines," BS EN 1998-4, 2006.
- [8] British Standards Institution, "Eurocode 8: Design of structures for earthquake resistance – Part 5: Foundations, retaining structures and geotechnical aspects," BS EN 1998-5, 2005.
- [9] British Standards Institution, "Eurocode 8: Design of structures for earthquake resistance – Part 6: Towers, masts and chimneys," BS EN 1998-6, 2006.
- [10] British Standards Institution, "UK National Annex to Eurocode 8: Design of structures for earthquake resistance – Part 1: General rules, seismic actions and rules for buildings," NA to BS EN 1998-1, 2008.
- [11] British Standards Institution, "UK National Annex to Eurocode 8: Design of structures for earthquake resistance – Part 2: Bridges," NA to BS EN 1998-2, 2009.
- [12] British Standards Institution, "UK National Annex to Eurocode 8: Design of structures for earthquake resistance – Part 4: Silos, tanks and pipelines," NA to BS EN 1998-4, 2008.
- [13] British Standards Institution, "UK National Annex to Eurocode 8: Design of structures for earthquake resistance – Part 5: Foundations, retaining structures and geotechnical aspects," NA to BS EN 1998-5, 2004.
- [14] British Standards Institution, "UK National Annex to Eurocode 8: Design of structures for earthquake resistance – Part 6: Towers, masts and chimneys," NA to BS EN 1998-6, 2008.
- [15] British Standards Institution, "Recommendations for the design of structures for earthquake resistance to BS EN 1998," PD 6698, 2009.
- [16] Chemical and Downstream Oil Industries Forum , "Guideline - Environmental Risk Tolerability for COMAH Establishments," v2.0, 2016.

APPENDIX A EXAMPLE CONSEQUENCE DESCRIPTIONS

A.1 Safety

Consequence	Population Density Per Hectare Within Hazard Zone
Low	≤ 2.5
Medium	$>2.5 \leq 20$
High	>20

Notes:

1. Hazard zone = radius of $4 \times$ building proximity distance (IGEM/TD/1) or $4 \times$ minimum distance to occupied building (PD 8010-1)
2. Population density ≤ 2.5 persons per hectare = Rural Area (IGEM/TD/1) and Class 1 (PD 8010-1)
3. Population density >2.5 persons per hectare = Suburban Area (IGEM/TD/1) and Class 2 (PD 8010-1)
4. Population density ≥ 20 persons per hectare is considered to represent higher population density Suburban Area (IGEM/TD/1) and higher population density Class 2 or Class 3 areas (PD 8010-1)

A.2 Example Economic, Social and Environmental Consequences

Consequence	Economic	Social	Environmental
Small	$< \text{£}10,000$	< 1000 homes without gas supply ≤ 1 home evacuated	Product loss $< 25 \text{ m}^3$
Considerable	$\text{£}10,000 \leq \text{£}100,000$	$1000 - 10,000$ homes without gas supply < 10 homes evacuated	Product loss $25 \text{ m}^3 \leq 100 \text{ m}^3$
Great	$> \text{£}100,000$	$> 10,000$ homes without gas supply > 10 homes evacuated	Product loss $> 100 \text{ m}^3$

Note: Economic threshold must be determined by the operator based on their business risk profile

APPENDIX B WORKED EXAMPLES

The following worked examples were developed applying the seismic screening methodology at a PIWG Seismic Screening workshop.

Case	Importance Class (IC)	Importance Factor (IF) y_i	PGA (Seismic Hazard Map) a_{Gr}	$a_g = y_i \times a_{Gr}$	$a_g \times S$		Seismic Assessment	
					Soil A $S = 1.0$	Soil D $S = 1.8$	Soil A	Soil D
1	Gas AGI R area, supply criticality high, IC = II	0.4500	0.0500	0.0225	0.0225	0.0405	None	None
2	Gas AGI R area, supply criticality high, IC = II	0.4500	0.0700	0.0315	0.0315	0.0567	None	None
3	Gas AGI S area, supply criticality medium, IC = II	0.4500	0.1500	0.0675	0.0675	0.1215	None	Simplified
4	Gas AGI R area, supply criticality high CNI, IC = III	1.0000	0.1300	0.1300	0.1300	0.2340	Full	Full
5	Gas import terminal, R area, supply criticality high CNI, IC = III	1.0000	0.0300	0.0300	0.0300	0.0540	Simplified	Simplified
6	Gas compressor station, R area, supply criticality high CNI, IC = III	1.0000	0.0700	0.0700	0.0700	0.1260	Simplified	Full
7	Gas compressor station, S area, supply criticality high CNI, IC = III	1.0000	0.0300	0.0300	0.0300	0.0540	Simplified	Simplified

Case	Importance Class (IC)	Importance Factor (IF) y_i	PGA (Seismic Hazard Map) a_{Gr}	$a_g = y_i \times a_{Gr}$	$a_g \times S$		Seismic Assessment	
					Soil A $S = 1.0$	Soil D $S = 1.8$	Soil A	Soil D
8	Liquid pump station, R area, supply criticality high, IC = II	0.4500	0.0500	0.0225	0.0225	0.0405	None	None
9	Gas AGI R area, supply criticality low, IC = I	0.0000	0.1500	0.0000	0.0000	0.0000	None	None
10	Gas AGI R area, supply criticality high, IC = II	0.4500	0.1100	0.0495	0.0495	0.0891	Simplified	Simplified
11	Gas pipeline R area, supply criticality high, IC = II	0.4500	0.1100	0.0495	0.0495	0.0891	None	None